

Annexure-2

Clarification of Bidders Queries raised by bidders in Pre-Bid meeting.

Name of Work:	Construction of IAQ and Balanced Ambient Calorimeter Chamber (extension of existing LECTB LAB), CEPT University, Ahmedabad.
Date & Time:	October 20, 2023 @ 12:00

Clarification of Bidders Queries:

<u>Sr No</u>	<u>Bidders' Query</u>	<u>Client's Reply</u>
1	List of approved makes for construction material required.	<i>Approved Make List uploaded on University Website as an Annexure-1</i>
2	Clarification on bill payment (payment cycle)	<i>Contractor can submit an RA bill on monthly basis</i>
3	Material Advance/ Mobilisation Advance will be paid or not	Payment against material delivery and Mobilization shall not be paid. (We shall follow the Monthly RA Bill payment process)
4	Unit of Measurement for BoQ Item No.: 25 (IPS 35-50 mm thk.) is in Cu. Mt.	<i>Will be measured in Cu. Mt. only</i>
5	Method for concrete making: In-situ or RMC	<i>RMC will be preferred. But in case of small quantity, in-situ can be allowed only if the contractor adhere to strict quality control during batching, mixing, and placing of concrete.</i>